

■銅管規格表

種別	空調用銅管			建築(給湯・給水)用銅管		
銅管 外径	呼び径 (JRA)	肉厚		呼び径 (JRA)	肉厚	
		汎用	JRA基準		L	M
6.35mm	2分	0.8mm	0.80mm			
9.52mm	3分	0.8mm	0.80mm	2分	0.76mm	
12.70mm	4分	0.8mm	0.80mm	3分	0.89mm	0.64mm
15.88mm	5分	1.0mm	1.00mm	4分	1.02mm	0.71mm
19.05mm	6分	1.0mm	1.00mm	5分	1.07mm	
22.22mm	7分	1.0mm	1.15mm	6分	1.14mm	0.81mm
25.40mm	1吋	1.0mm	1.30mm			
28.58mm	1吋1分	1.2mm	1.40mm	1吋	1.27mm	0.89mm
31.75mm	1吋2分	1.2mm	1.50mm			
34.92mm	1吋3分	1.2mm	1.65mm	1吋2分	1.40mm	1.07mm
38.10mm	1吋4分	1.4mm	1.80mm			
41.28mm				1吋4分	1.52mm	1.24mm

※JRA:(社)日本冷凍空調工業会